

VOC Content Test Certificate

Friday October 19th, 2007

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills NSW 2147)

Sample Description: Ardex AF143 (pressure sensitive vinyl adhesive)

Date Tested: October 2007 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification	
Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Ardex AF143
Rubber Flooring Adhesive 60 grams per Litre	30 grams per Litre
Specification	
Green Building Council of Australia Green Star Office Design V3 IEQ-13	Ardex AF143
Rubber Flooring Adhesive 60 grams per Litre	30 grams per Litre



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0710-15