

# VOC Content Test Certificate

Tuesday, March 08, 2011

Supplier: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills NSW 2147)

Sample Description: ARDEX AF 172 Acrylic Sheet Vinyl Adhesive

Date Tested: October 2007 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ-13</b> <b>Green Star Office Interiors V1.1</b> <b>IEQ-11</b>	<b>Ardex AF 172</b>
Rubber Flooring Adhesive 60 grams per Litre as VOC content material	<b>48 grams per Litre as VOC content                  material</b>



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant

**F0710-15**