

VOC Content Test Certificate

Thursday December 4th, 2008

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road Seven Hills NSW 2147)

Sample Description: Ardex Optima two part premium tile adhesive

Date Tested: December 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Ardex Optima
Ceramic Tile Adhesive 65 grams per Litre as VOC content material	25 grams per Litre as VOC content per coating
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Ardex Optima
Ceramic Tile Adhesive 65 grams per Litre as VOC content material	25 grams per Litre as VOC content per coating



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0811-34