



Consulting Enterprises in Technology

SCIENTIFIC CONSULTANTS IN RISK ASSESSMENT AND MANAGEMENT, PRODUCTS, PROCESSES, OH&S, ENVIRONMENT

VOC Content Test Certificate

Friday July 4th, 2008

Manufacturer: Ardex Australia Pty Ltd

Unit 7, 20 Powers Road

Seven Hills NSW 2147

Sample Description: ARDEX LQ 92 under tile levelling compound

Date Tested: June 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification	
Green Building Council of Australia	ARDEX LQ 92
Green Star Office Design V2 IEQ -13	
Green Star Office Design V3 IEQ -13	
Green Star Office Interiors V1.1 IEQ -11	
Sub-Floor Adhesive 50 grams per Litre maximum	5 grams per Litre

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0806-39