

VOC Content Test Certificate

Tuesday, 06th February 2018

Supplier: Ardex Australia Pty Ltd (7/20 Power Road, Seven Hills NSW 2147).

Sample Description: Ardex PU 30

Date Tested: 25 January 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B	Ardex PU30
General Purpose Adhesives and Sealants: 50 grams per Litre as VOC content per material	13 grams per Litre as VOC content per material
<i>We hereby certify Ardex PU30 is well below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV180150