BRANZ
1222 Moonshine Road
Judgeford RD1
Porirua 5381
New Zealand
T +64 4 237 1170
F +64 4 237 1171
branz@branz.co.nz
www.branz.co.nz

SUMMARY REPORT

DC13305-010-3

SUMMARY ON TESTING OF ARDEX WPM 444 MEMBRANE TO THE REQUIREMENTS OF AS 4654.1-2012

CLIENT
Ardex Australia Pty Ltd
20 Powers Road
Seven Hills
NSW 2147
AUSTRALIA

THE LEGAL VALIDITY OF THIS REPORT CAN ONLY BE CLAIMED ON PRESENTATION OF THE COMPLETE SIGNED PAPER REPORT. EXTRACTS OR ABRIDGMENTS OF THIS REPORT SHALL NOT BE PUBLISHED WITHOUT PERMISSION FROM BRANZ LTD.

TEST SUMMARY

Objective

Testing was completed of the WPM 444 to the requirements of AS 4654.1-2012 *Waterproofing membranes for external above-ground use Part 1: Materials.*

Summary

Passing results were obtained for the 3.95 mm thick WPM 444 membrane where requirements are stated in the AS 4654.1-2012 Standard. The WPM 444 membrane samples supplied met the requirements to be classified as Class II (Medium Extensibility).

Test sponsor

Ardex Australia Pty Ltd
20 Powers Road
Seven Hills
NSW 2147
AUSTRALIA

Description of test specimen

The client supplied sheet membrane samples to be tested. The samples were assigned the BRANZ sample reference 21/047.

Date of test

Testing completed on 9 April 2021.

LIMITATION

The results reported here relate only to the items tested.

TERMS AND CONDITIONS

This report is issued in accordance with the Terms and Conditions as detailed and agreed in the BRANZ Services Agreement for this work.

THE LEGAL VALIDITY OF THIS REPORT CAN ONLY BE CLAIMED ON PRESENTATION OF THE COMPLETE SIGNED PAPER REPORT.
EXTRACTS OR ABRIDGMENTS OF THIS REPORT SHALL NOT BE PUBLISHED WITHOUT PERMISSION FROM BRANZ LTD.

SIGNATORIES

Author

Holly Moody
Materials Technician
BRANZ

Reviewer

Konrad Suschke
Materials Scientist
BRANZ

DOCUMENT REVISION STATUS

ISSUE NO.	DATE ISSUED	DESCRIPTION
1	15 April 2021	Initial Issue
2	4 August 2026	Report expiry date extended while re-validation testing is underway
3	29 October 2026	Report expiry date extended while re-validation testing is underway

THE LEGAL VALIDITY OF THIS REPORT CAN ONLY BE CLAIMED ON PRESENTATION OF THE COMPLETE SIGNED PAPER REPORT. EXTRACTS OR ABRIDGMENTS OF THIS REPORT SHALL NOT BE PUBLISHED WITHOUT PERMISSION FROM BRANZ LTD.