



ARDEX Australia Pty Ltd ABN 82 000 550 005  
20 Powers Road Seven Hills NSW 2147 Australia  
Telephone + 61 2 9851 9199 Facsimile +61 2 9674 5621 [www.ardex.com](http://www.ardex.com)

ARDEX WPM 310 White, page 1 of 1

## CERTIFICATE OF COMPLIANCE

Date Issued: 30 January 2024  
Date of Testing: 23 November to 19 December 2023  
Type of Sample Tested: ARDEX WPM 310 White

### Product Characterisation

General purpose waterproof coating with excellent UV resistance

### Main Ingredients

- 100% Acrylic emulsion
- Fillers

### Field of Application

- Concrete, rendered walls, brick/masonry walls, Fibre cement sheets, tilt up and pre-cast concrete, light weight aerated concrete blocks

### Test Method

Solar Reflectance (%)\*  
Solar Absorptance (%)\*  
Solar Reflective Index (SRI)\*

### Test Results

83.7%  
16.3%  
106

\*Tested in accordance with ASTM E903 (reflectance and absorptance) and ASTM E1980 (SRI) at Optics and Radiometry Laboratory UNSW

ARDEX Australia Pty. Ltd.

Tony Grozdanovski  
Senior Chemist

Steve Wood  
R&D Manager