



ARDEX Australia Pty Ltd ABN 82 000 550 005
20 Powers Road Seven Hills NSW 2147 Australia
Telephone + 61 2 9851 9199 Facsimile +61 2 9674 5621 www.ardex.com

ARDEX WPM 715, page 1 of 1

CERTIFICATE OF COMPLIANCE

Date Issued: 30 January 2024
Date of Testing: 23 November to 19 December 2023
Type of Sample Tested: ARDEX WPM 715 Weldable Waterproofing Membrane

Product Characterisation

Weldable waterproofing membrane

Main Ingredients

- Isobutylene homopolymer
- Isoprene homopolymer
- Polyolefins
- Stabilisers

Field of Application

- Can be used as a single layer waterproofing membrane in both horizontal and vertical applications for UV exposed environments such as decks and rooftops.

Test Method


Solar Reflectance (%)*
Solar Absorptance (%)*
Solar Reflective Index (SRI)*


Test Results

24.9%
75.1%
27

*Tested in accordance with ASTM E903 (reflectance and absorptance) and ASTM E1980 (SRI) at Optics and Radiometry Laboratory UNSW

ARDEX Australia Pty. Ltd.


Tony Grozdanovski
Senior Chemist


Steve Wood
R&D Manager