



ARDEX Australia Pty Ltd ABN 82 000 550 005
20 Powers Road Seven Hills NSW 2147 Australia
Telephone + 61 2 9851 9199 Facsimile +61 2 9674 5621 www.ardex.com

ARDEX WPM 822, page 1 of 1

CERTIFICATE OF COMPLIANCE

Date Issued: 30 January 2024
Date of Testing: 23 November to 19 December 2023
Type of Sample Tested: ARDEX WPM 822

Product Characterisation

Two component UV stable, abrasion resistant, polyurethane topcoat for low to medium pedestrian traffic.

Main Ingredients

- Aliphatic polyurethane
- Solvents
- Fillers

Field of Application

- Exposed decks, plant room floors, roofs, box gutters, balconies, terraces
- Can also be used as a resilient impact resistant flooring finish in gymnasiums, sports centres, laboratories, etc.

Test Method


Solar Reflectance (%)*
Solar Absorptance (%)*
Solar Reflective Index (SRI)*

Test Results

22.3%
77.7%
22

*Tested in accordance with ASTM E903 (reflectance and absorptance) and ASTM E1980 (SRI) at Optics and Radiometry Laboratory UNSW

ARDEX Australia Pty. Ltd.


Tony Grozdanovski
Senior Chemist


Steve Wood
R&D Manager