



ARDEX Australia Pty Ltd ABN 82 000 550 005
20 Powers Road Seven Hills NSW 2147 Australia
Telephone + 61 2 9851 9199 Facsimile +61 2 9674 5621 www.ardex.com

ARDEX WPM 823, page 1 of 1

CERTIFICATE OF COMPLIANCE

Date Issued: 30 January 2024
Date of Testing: 23 November to 19 December 2023
Type of Sample Tested: ARDEX WPM 823

Product Characterisation

Two component, fast curing, hybrid, UV stable polyurethane coating designed as a trafficable impact resistant finish.

Main Ingredients

- Polyurethane
- Solvents
- Fillers

Field of Application

- Exposed decks, car parks, ramps, loading docks,
- Can also be used as a standalone durable finish on walkways, resilient impact resistant flooring finish in gymnasiums, sports centres, laboratories, etc.

Test Method

Solar Reflectance (%)*
Solar Absorptance (%)*
Solar Reflective Index (SRI)*

Test Results

20.0%
80.0%
19

*Tested in accordance with ASTM E903 (reflectance and absorptance) and ASTM E1980 (SRI) at Optics and Radiometry Laboratory UNSW

ARDEX Australia Pty. Ltd.

Tony Grozdanovski
Senior Chemist

Steve Wood
R&D Manager