

## ANALYSIS CERTIFICATE

**2 September, 2022**

<b>OUR REF:</b>	<b>108009A</b>
<b>TO:</b>	<b>Ardex NZ Ltd</b>
<b>ATTN:</b>	<b>Steven Irvine</b>

<b>SAMPLE OF:</b>	<b>Ardex A38</b>	<b>SAMPLE TYPE:</b>	<b>As received</b>
<b>SAMPLE TYPE:</b>	<b>Rapid Set Screed Cement</b>	<b>DATE RECEIVED:</b>	<b>31/08/2022</b>
<b>SAMPLE DATE:</b>	<b>-</b>	<b>DATE TESTED:</b>	<b>01-02/09/2022</b>
		<b>ORDER NO:</b>	<b>VOC testing</b>

	<b>Result</b>	<b>Method</b>
Total Non-Volatile Content, %w/w	<b>99.5</b>	<i>Oven-drying @ 110°C (60mins)</i>
Total Water Content, %w/w	-	<i>Karl Fischer titration</i>
Density, g/mL	<b>1.34</b>	<i>Gravimetry</i>
Exempt Compounds	<b>None specified</b>	

	<b>Result</b>	<b>Method</b>
Total Volatile Organic Compounds, g/L	<b>&lt;7</b>	<i>SCAQMD METHOD 304-91</i>

  
 \_\_\_\_\_  
 Analyst

  
 \_\_\_\_\_  
 Authorised by

This report relates only to the sample provided

**This Report Shall Not Be Reproduced Except In Full**  
**MEMBER OF THE NEW ZEALAND ASSOCIATION OF CONSULTING LABORATORIES**