

VOC Content Test Certificate

Monday 15th March 2021

Supplier: Ardex Australia Pty Ltd (7/20 Powers Road, SEVEN HILLS, 2147, NSW, Australia).

Sample Description: Ardex AF171 Universal Vinyl Adhesive

Date Tested: February 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:


<p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B</p>	<p align="center">Ardex AF171 Universal Vinyl Adhesive</p>
<p align="center">General Purpose Adhesives and Sealants Limit: ≤ 50 grams per liter</p>	<p align="center">22 grams per Litre as VOC content per material</p>
<p align="center">Meets GBCA VOC Content Requirement</p>	<p align="center">Yes</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Dr Srikanth C. Srivatsa
PhD (Chemistry)
Consultant

V2102057