

# VOC Content Test Certificate

Friday, 12<sup>th</sup> January 2018

Supplier: Ardex Australia Pty Ltd (7/20 Powers Road, Seven Hills, NSW 2147).

Sample Description: Ardex AF 180 MS, One Component Heavy Duty Adhesive

Date Tested: January 2017 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.1 13.1.1</b> <b>Green Star Interiors V1.1 12.1.1B</b>	<b>Ardex AF 180MS,</b> <b>One Component</b> <b>Heavy Duty Adhesive</b>
General purpose adhesives and sealants: 50 grams per Litre as VOC content per material	<b>&lt;13 grams per Litre as VOC</b> <b>content per material</b>
<b><i>We hereby certify Ardex AF 180 MS is well below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></b>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BE (Chem. Eng.)  
Consultant



Nick Joy  
BSc (Hons)  
Consultant

CV171205