

VOC Content Test Certificate

Tuesday April 12th, 2011

Manufacturer: Ardex (20 Powers Road, Seven Hills, NSW, 2147)

Sample Description: Ardex AF 236

Date Tested: March 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 303-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Ardex AF 236
Carpet pad adhesive 50 grams per Litre as VOC content material	<1 gram per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1104-04