

# VOC Content Test Certificate

Wednesday 20<sup>th</sup> November 2024

Supplier: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills, NSW 2147, Australia)

Product Description: ARDEX Fine Finish Smoothing Compound

Date Tested: 1 November 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 & ASTM D2369 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3-13.1.1B</b> <b>Green Star Interiors V1.3-12.1.1B</b>	<b>ARDEX Fine Finish Smoothing Compound</b>
<b>General Purpose Adhesives and Sealants Limit:</b> <b>50 grams per litre</b>	<b>2 grams per litre as VOC content per material</b>
<b>Meets GBCA VOC Content Requirement</b>	<b>Yes</b>

Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

Dr. Tuan Duong  
PhD, BE (Chem. Eng.)  
Senior Consultant

Travis Hale  
BSc (Biotechnology)  
Senior Consultant

Issue date: 20/11/2024

Expiry date: 20/11/2029

P24100122