

# VOC Content Test Certificate

Thursday October 23<sup>rd</sup>, 2008

Manufacturer: Ardex Australia Pty Ltd

Unit 7, 20 Powers Road

Seven Hills NSW 2147

Sample Description: Ardex Arditex NA (sub floor leveling and smoothing compound)

Date Tested: October 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ-13</b> <b>Green Star Office Interiors V1.1 IEQ-11</b>	<b>Ardex Arditex NA</b>
Architectural sealant 250 grams per Litre as VOC content coating	<b>64 grams per Litre as VOC content per coating</b>
<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b>	<b>Ardex Arditex NA</b>
Architectural sealant 250 grams per Litre as VOC content coating	<b>64 grams per Litre as VOC content per coating</b>



Dr. Vyt Garnys

PhD, BSc(Hons) AIMM, ARACI, ISIAQ

ACA, AIRAH, FMA

Managing Director and Principal Consultant

F0810-19