

VOC Content Test Certificate

Friday August 7th, 2009

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road Seven Hills NSW 2147)

Sample Description: Ardex Abalastic additive for cement based adhesives

Date Tested: July 2009 (Tested by FORAY Laboratory – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

	Ardex Abalastic
Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	52 grams per Litre as VOC content material
	Ardex Abalastic
Green Building Council of Australia Green Star Office Design V3 IEQ-13	52 grams per Litre as VOC content material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0907-28