

# VOC Content Test Certificate

Wednesday 5<sup>th</sup> April 2023

Supplier: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills, NSW 2147, Australia)

Sample Description: Ardex WA 100

Date Tested: March 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

|  |   |
|--|---|
| <b>Specification</b><br>South Coast Air Quality Management District<br>Rule 1168 – Adhesive and Sealant Applications | <b>Ardex WA 100</b>                                   |
| <b>Ceramic Glass, Porcelain, &amp; Stone Tile Adhesive Limit:</b><br>65 grams per litre                              | <b>60 grams per litre as VOC content per material</b> |
| <b>Meets SCAQMD VOC Content Requirement</b>  | <b>Yes</b>  |



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Tuan Duong  
PhD, BE (Chem. Eng.)  
Senior Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant

Issue date: 23/04/2023

Expiry date: 23/04/2028

P23020085