

# VOC Content Test Certificate

Friday August 7<sup>th</sup>, 2009

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road Seven Hills NSW 2147)

Sample Description: Ardex WA grouting compound

Date Tested: July 2009 (Tested by FORAY Laboratory – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ-13</b> <b>Green Star Office Interiors V1.1 IEQ-11</b>	<b>Ardex WA</b>
Ceramic tile adhesive 65 grams per Litre as VOC content material	<b>20 grams per Litre as VOC content material</b>
<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b>	<b>Ardex WA</b>
Ceramic tile adhesive 65 grams per Litre as VOC content material	<b>20 grams per Litre as VOC content material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

**F0907-28**