

# VOC Content Test Certificate

Tuesday 25<sup>th</sup> October 2022

**Supplier** Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills, NSW 2147, Australia).

**Sample Description** Ardex X77 22G08V

**Date Tested** October 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

**Test Method** ASTM D3960 & ASTM D2369 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred to in accordance with the laboratory testing guidance from the Green Building Council of Australia.

## Test Results

<p align="center"><b>Specification</b></p> <p align="center"><b>Green Building Council of Australia</b></p> <p align="center"><b>Green Star Design &amp; As Built V1.3-13.1.1B</b></p> <p align="center"><b>Green Star Interiors V1.3-12.1.1B</b></p>	<p><b>Ardex X77 22G08V</b></p>
<p align="center"><b>General Purpose Adhesives and Sealants Limit:</b></p> <p align="center"><b>50 grams per litre</b></p>	<p><b>1 gram per litre as VOC content per material</b></p>
<p><b>Meets GBCA VOC Content Requirement</b></p>	<p><b>Yes</b></p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Tuan Duong  
PhD, BE (Chem. Eng.)  
Senior Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant

**P22090047**