

VOC Content Test Certificate

Thursday, 27th June 2019

Supplier: Ardex Australia Pty Ltd (7/20 Powers Road, Seven Hills, NSW, 2147, Australia)

Sample Description: Ardex WPM 710 Grey

Date Tested: 24th June 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p>Specification</p> <p>Green Building Council of Australia Green Star Design & As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B</p>	<p>Ardex WPM 710 Grey</p>
<p>Acoustic sealants, architectural sealants, waterproofing membranes and sealants, fire retardant sealants and adhesives: 250 grams per Litre as VOC content per material</p>	<p>4 grams per Litre as VOC content per material</p>
<p><i>We hereby certify Ardex WPM 710 Grey is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant



Tuan Duong
 BE (Chem. Eng.)
 Consultant



Luke Morley
 BSc (Tech)
 Consultant

CV190661